



NOTES:

1. PAVEMENT THICKNESS VARIES AND MUST BE REPLACED IN KIND, BUT NOT LESS THAN TWO INCHES.
2. SAW-CUT PAVEMENT TO PRODUCE A STRAIGHT VERTICAL FACE AGAINST WHICH TO BUTT THE NEW PAVEMENT.

STD015

SOQUEL CREEK WATER DISTRICT

P.O. BOX 1550 CAPITOLA, CALIFORNIA 95010

CAD: AJB

DATE: AUGUST 2019

CHECKED: MJW

APPROVED: TAD

TRENCH BACKFILL LATERAL (CROSS) TRENCHES SAND/CEMENT SLURRY

STD. NO.

S-15